

**SE SULLIVAN ELECTRIC
& PUMP, INC.**

1942 8th Ave North Lake Worth, FL 33461
 Florida License #EC0001117
 Voice (561) 588-5886 / (800) 991-2770 Fax (561) 582-9344
 E Mail: Sales@sullivanelectric-pump.com


Invoice

Date	Invoice #
11/15/2019	12443

Bill To
Dwayne Sprinkler Repair Inc. 3024 NE 17th Ave Pompano Beach, FL 33064

Ship To
800 NW 110th Lane Coral Springs, FL 33067

P.O. No.	Terms	Rep	Ship Date	FOB	Project
Signed Quote	Net 30	KC	11/15/2019	Randy	S-3932
Qty	Description	Price	Amount		
	Estimate 15148 QUOTED BY: K.C. LAZERE REQUESTED BY: DWAYNE LOCATION: CYPRESS LAKES DESCRIPTION: 10HP CLOCK START MOTOR. 7.5HP WEG MOTOR. PUMP GRISWOLD SERIAL: 19MAR17 JOB# S-3932 PO#	0.00	0.00T		
2	Shop Labor REPLACE MOTOR AND REBUILD PUMP	80.00	160.00T		
1	10HP WEG 213JM 3600RPM 1PH TEFC 10HP 3600 1 60 208-230V	1,389.64	1,389.64T		
1	AS-165 O-RING (70 DUROMETER)	1.64	1.64T		
1	S-185 1.250" SEAL TYPE 21 FLOWSERVE	30.53	30.53T		
1	Griswold Shaft Sleeve 1-1/4"	24.96	24.96T		
3	Service Technician TO DATE 10/25/19 ROBERT ONSITE FOUND BAD GFCI RECEPTACLE HANGING OUT BOX, REPLACED AND INSTALLED BUBBLE COVER THEN PULLED PUMP FOR REPAIR	102.00	306.00		
1	1 GANG IN USE VERT/HORIZ PLASTIC COVER	18.98	18.98T		
1	15A 125V SELF TEST GFCI RCPT WHT	29.98	29.98T		
3	Service Technician RETURN TO SITE AND RE-INSTALL AND TEST PUMP	102.00	306.00		
		Subtotal			
		Sales Tax (6.0%)			
		Total			
		Payments/Credits			
		Balance Due			



1942 8th Ave North Lake Worth, FL 33461
 Florida License #EC0001117
 Voice (561) 588-5886 / (800) 991-2770 Fax (561) 582-9344
 E Mail: Sales@sullivanelectric-pump.com

Invoice

Date	Invoice #
11/15/2019	12443

Bill To
Dwayne Sprinkler Repair Inc. 3024 NE 17th Ave Pompano Beach, FL 33064

Ship To
800 NW 110th Lane Coral Springs, FL 33067

P.O. No.	Terms	Rep	Ship Date	FOB	Project
Signed Quote	Net 30	KC	11/15/2019	Randy	S-3932
Qty	Description	Price	Amount		
	****MOTOR WAS ORIGINAL SOLD ON 4/5/18 PER QUOTE 10707 AND IS BEYOND ONE YEAR OLD. MOTOR WAS OVERLOADED, POSSIBLE OVERDEMAND IN FIELD OR MOTOR STARTER NOT SET PROPERLY.****	0.00	0.00T		
	Total Reimbursable Expenses		0.00		
				Subtotal	\$2,267.73
				Sales Tax (6.0%)	\$99.34
				Total	\$2,367.07
				Payments/Credits	\$0.00
				Balance Due	\$2,367.07


**SULLIVAN ELECTRIC
& PUMP, INC.**

1942 8th Ave North Lake Worth, FL 33461
 Florida License #EC0001117
 Voice (561) 588-8886 / (800) 991-2770 Fax (561) 582-9344
 E Mail: sales@sullivanelectric-pump.com

Invoice

Date	Invoice #
12/19/2019	12602

Bill To
Dwayne Sprinkler Repair Inc. 3024 NE 17th Ave Pompano Beach, FL 33064

Ship To
800 NW 110th Lane Coral Springs, FL 33067

P.O. No.	Terms	Rep	Ship Date	FOB	Project
	Net 30	KC	12/19/2019		S-4138
Qty	Description	Price	Amount		
	DESCRIPTION OF WORK AS PER SULLIVAN QUOTE #15571:		0.00		
2.5	CYPRESS LAKES 10HP FOLLOW UP REPAIRS MADE AND NEEDED TO GET STATION RUNNING. Field Service Technician 11/22/19 AFTER RE-INSTALLING PUMP MOTOR STARTER AND OVERLOAD WERE BAD. REPLACED BOTH SO STATION COULD RUN, HAD TO CLOSE ISOLATION VALVE TO LOWER RUNNING AMPS, FOUND MAIN LINE BREAKS CALLED CUSTOMER TO HAVE BREAKS REPAIRED SO WE COULD RETURN TO CHECK AMPS. NEW STARTER INSTALLED 12/16/19	102.00	255.00		
1	SIZE 3 CONTACTOR 90 AMP, 100 - 250 VAC COIL ABB ABB OVERLOAD 48.0 - 60.0 AMP SETTING AF80, AF96 ****CUSTOMER REQUESTING PRESSURE TANK START SYSTEM TO BE INSTALLED, BUT BASED ON SPACE AND SYSTEM OPERATION SULLIVAN BELIEVES THIS WOULD CAUSE MORE PROBLEMS AND ISSUES THEN LEAVING SYSTEM AT CLOCK START DESIGN.****	387.22 144.04 0.00	387.22T 144.04T 0.00T		
	Total Reimbursable Expenses		0.00		
			Subtotal	S786.26	
			Sales Tax (6.0%)	S31.88	
			Total	S818.14	
			Payments/Credits	S0.00	
			Balance Due	S818.14	